

Product fiche

Delegated Regulation (EU) 811/2013

Seasonal space heating energy efficiency of boiler

37 %

Temperature control

From fiche of temperature control

Class I = 1 %, Class II = 2 %, Class III = 1.5 %,
Class IV = 2 %, Class V = 3 %, Class VI = 4 %,
Class VII = 3.5 %, Class VIII = 5 %

+ [-] %

Supplementary boiler

From fiche of boiler

Seasonal space heating energy efficiency (in %)

([-] - 37) x 0.1 = ± [-] %

Solar contribution

From fiche of solar device

Collector size
(in m²)

Tank volume
(in m³)

Collector efficiency
(in %)

Tank rating
A⁺ = 0.95, A = 0.91,
B = 0.86, C = 0.83,
D-G = 0.81

([-] x [-] + [-] x [-]) x 0.9 x ([-] / 100) x [-] = + [-] %

Supplementary heat pump

From fiche of heat pump

Seasonal space heating energy efficiency (in %)

([-] - 37) x 0 = + [-] %

Solar contribution AND Supplementary heat pump

Select smaller value

0.5 x [-] OR 0.5 x [-] = - [-] %

Seasonal space heating energy efficiency of package

39 %

Seasonal space heating energy efficiency class of package



Boiler and supplementary heat pump installed with low temperature heat emitters at 35 °C?

From fiche of heat pump

39 + (50 x 0) = [-] %

The energy efficiency of the package of products provided for in this fiche may not correspond to its actual energy efficiency once installed in a building, as the efficiency is influenced by further factors such as heat loss in the distribution system and the dimensioning of the products in relation to building size and characteristics.

Model placed on the Union market from 08/10/2020



EPREL registration number: 379493

<https://eprel.ec.europa.eu/qr/379493>

Supplier: Värmebaronen AB (Manufacturer)

Website: varmebaronen.se

Customer care service:

Name: Värmebaronen

Website:

Email: info@varmebaronen.se

Phone: 044226320

Address:

Arkelstorpsvägen 88
Sweden